


LETTER CODE FOR IDENTIFICATION OF INSTRUMENT FUNCTION

LETTER	FIRST LETTER		SUCCEEDING LETTER		
	MEASURED OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A	ANALYSIS	-	ALARM	-	-
B	BURNER, FLAME	-	STATE OR STATUS	USERS CHOICE	USERS CHOICE
C	USERS CHOICE	-	-	CONTROL	CLOSED
D	DENSITY	DIFFERENTIAL	-	-	-
E	VOLTAGE	-	SENSOR	-	-
F	FLOW RATE	RATIO	-	-	-
G	GUAGING POSITION OR LENGTH	-	VIEWING DEVICE	-	-
H	HAND	-	-	-	HIGH
I	CURRENT (ELECTRICAL)	-	INDICATOR	-	-
J	POWER	SCAN	-	-	-
K	TIME, TIME SCHEDULE	TIME RATE OF CHANGE	BARRIER	CONTROL STATION	-
L	LEVEL	-	LIGHT	-	LOW
M	MOISTURE	MOMENTARY	-	-	MIDDLE INTERMEDIATE
N	USERS CHOICE	-	USERS CHOICE	USERS CHOICE	USERS CHOICE
O	USERS CHOICE	-	ORIFICE RESTR.	-	OPEN OR OVERFLOW
P	PRESSURE, VACUUM	-	POINT CONNECTION	-	-
Q	QUANTITY	INTERGRATE, TOTALIZE	INTERGRATE OR SUMMATION	-	-
R	RADIATION	-	RECORD	-	-
S	SPEED, FREQUENCY	SAFETY	-	SWITCH	-
T	TEMPERATURE	-	-	TRANSMIT	-
U	MULTIVARIABLE	-	MULTI FUNCTION	MULTI FUNCTION	MULTI FUNCTION
V	VIBRATION, MECHANICAL ANALYSIS	-	-	VALVE, DAMPER, LOUVER	-
W	WEIGHT, FORCE	-	WELL	-	-
X	UNCLASSIFIED	X AXIS	CATHODE RAY TUBE	-	UNCLASSIFIED
Y	EVENT, STATE OR PRESENCE	Y AXIS	-	RELAY, COMPUTE, CONVERT	-
Z	POSITION, DIMENSION	Z AXIS	EMERGENCY OR SAFETY ACTING	DRIVER, ACTUATOR, UNCLASSIFIED FINAL CONTROL ELEMENT	-

GWF TAG NUMBERING



NOTES
 1. FOR COLOR DEFINITIONS REFER COR/02/22774
 2. SYMBOL REFERENCES DERIVED FROM DRAWING A2-32919 AND A3-35200

REV.	DATE	DESCRIPTION	APP'D	TITLE
2	12/8/16	ADDED PIPE SPECIFICATION AND PLC/RTU TO FUNCTION SYMBOLS	GSN	
1	27/8/15	APPROVED FOR ISSUE	GSN	

DESIGNED BY:	PLAN No.	TITLE

DO NOT SCALE GIPPSLAND WATER DRAWING STATUS **APPROVED FOR ISSUE**

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.

DESIGNED: / /
 DRAWN: 2/4/16 GSN
 CHECKED: 27/8/15 G.B SMITH

GIPPSLAND WATER
 PROCESS AND INSTRUMENT STANDARD SYMBOLS AND CODES

DRAWING No. **A1-58517** REV. **2**