



REV	DATE	DESCRIPTION	APP'D	PLAN No.	TITLE	DESIGNED BY:	DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX	DRAWING No. A1-52788	REV. 4
4	27/9/21	SPLIT CONTROL & TELEMETRY COMPARTMENT INTO SEPARATE COMPARTMENTS.	P.S.									
3	21/5/21	REVISED JUNCTION BOX DETAILS FOR PUMPS UP TO 45kW.	P.S.									
2	7/9/20	UPDATED DRAWING SHEETS REV SURGE LINE9 ADDED GEN & MAINS AUX. CONTACTS.	P.J.									
1	18/3/13	REVISED SURGE DIVERTER AUX CONTACTS.	P.J.									
0	24/9/12	INITIAL ISSUE.	P.J.									

REFERENCES

A1-52770

STD SPS - PUMP STN 30kW TO 160kW (VSD) - CT METERED - I & C - DRG INDEX

OPTIMUM
DRAFTING PTY LTD

A.B.N. 28 065 272 942

CERTIFICATION OF
COMPLIANCE WITH
GIPPSLAND WATER'S
DESIGN & DRAFTING
REQUIREMENTS.

DESIGNED:
25/01/2018 - STD DRG

DRAWN:
25/01/2018 - OPT/CT

CHECKED:
25/01/2018 - P STEWART

GIPPSLAND WATER

STANDARD SEWERAGE PUMP STATION
PUMP STATION 30kW TO 160kW (VSD) - CT METERED
'ACE3600' TELEMETRY SLOT 1 - MIXED I/O CARD
ELECTRICAL SCHEMATIC DIAGRAM - SHEET 1 OF 2