




SECTION "B-B"  
REFER DRG A1-52826




SECTION "A-A"  
REFER DRG A1-52826



SECTION "D-D"  
REFER DRG A1-52826




SECTION "E-E"  
REFER DRG A1-52826





SECTION "F-F"  
REFER DRG A1-52826


200H x 550W GLAND PLATES  
TO BE CUT IN EITHER TOP OR BOTTOM  
OF VSD AND PHF COMPARTMENTS.



SECTION "C-C"  
REFER DRG A1-52826



DETAIL "A"  
EARTH BRAIDS FASTENING



DETAIL "B"  
OPEN DOOR

DETAIL "B"  
CLOSED DOOR

REVISIONS	No.	DATE	DESCRIPTION	APP'D
	5	23/9/21	SPLIT CONTROL & TELEMETRY COMPARTMENT INTO SEPARATE COMPARTMENTS.	P.S.
	4	21/5/21	REVISED VSD FAN LOCATIONS.	P.S.
	3	7/9/20	UPDATED DRAWING SHEETS.	P.S.
	2	9/10/13	REVISED DRAWING.	M.B.
	1	18/3/13	ADDED EARTH BRAIDS.	P.J.
	0	24/9/12	INITIAL ISSUE.	P.J.

DESIGNED BY:

**OPTIMUM**  
DRAFTING PTY LTD  
A.B.N. 28 065 272 942

DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.	DRAWN: 25/01/2018 - OPT/CT CHECKED: 25/01/2018 - P STEWART	<b>GIPPSLAND WATER</b>	DRAWING No. A1-52827
		STANDARD SEWERAGE PUMP STATION PUMP STATION 30kW TO 160kW (VSD) - CT METERED VSD CUBICLE SECTIONAL ARRANGEMENT	REV. 5