

NOTE:
UNLESS OTHERWISE INDICATED
ALL DIN RAIL TO BE STOOD OFF FROM
GEAR TRAY BY A NOMINAL 40mm.

No.	DATE	DESCRIPTION	APP'D	PLAN No.	TITLE
3	23/9/21	SPLIT GEAR TRAYS AND TELEMETRY GEAR TRAY ON DRG A1-74337.	P.S.		
2	7/9/20	UPDATED DRG SHTS & SURGE TYPE ADDED TS12 MEM BLOCK & 12/24V CONV.	P.S.		
1	9/10/13	REVISED DRAWING.	M.B.		
0	24/9/12	INITIAL ISSUE.	P.J.		

DESIGNED BY:

OPTIMUM

DRAFTING PTY LTD

A.B.N. 28 065 272 942

DO NOT SCALE

GIPPSLAND WATER
DRAWING STATUS

STANDARD DRAWING


GIPPSLAND WATER FACILITY CODE
XXCPXX

CERTIFICATION OF
COMPLIANCE WITH
GIPPSLAND WATER'S
DESIGN & DRAFTING
REQUIREMENTS.

DESIGNED:
25/01/2018 - STD DRG

DRAWN:
25/01/2018 - OPT/CT

CHECKED:
25/01/2018 - P STEWART



GIPPSLAND WATER

STANDARD SEWAGE PUMP STATION
PUMP STATION 55kW TO 160kW (VSD) - CT METERED
VSD CUBICLE - CONTROL COMPARTMENT
GEAR TRAY LAYOUT

DRAWING No.
A1-52845

REV.
3