

NOTE:
DO NOT PAINT OR POWDER COAT
THE VSD/PHF GEAR TRAY

50 x 6 ALUMINIUM FLAT BAR
WELDED TO BACK OF GEAR TRAY

REVISONS				REFERENCES		
	No.	DATE	DESCRIPTION		PLAN No.	TITLE
	1	29/3/21	STANDARD DRAWING.	P.S.	A1-47775	STD SPS - PUMP STN 7.5kW TO 22kW (VSD) - DIRECT METERED - I & C - DRG INDEX

DESIGNED BY:




OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

DO NOT SCALE

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.
DESIGNED: 19/04/2010 - GW/STD
DRAWN: 29/03/2021 - OPT/RJ
CHECKED: 31/03/2021 - P STEWART

GIPPSLAND WATER



STANDARD DRAWING

DRAWING No. A1-72836

REV. 1

STANDARD SEWAGE PUMP STATION

PUMP STATION 7.5kW TO 22kW (VSD) - DIRECT METERED

VSD P22K & AHF 130B1111 (40A)

GEAR TRAY LAYOUT

GIPPSLAND WATER FACILITY CODE

XXCPXX