



NOTE:
DO NOT PAINT OR POWDER COAT
THE VSD/PHF GEAR TRAY

50 x 6 ALUMINIUM FLAT BAR
WELDED TO BACK OF GEAR TRAY

REVISIONS

No.	DATE	DESCRIPTION	APP'D
1	29/3/21	STANDARD DRAWING.	P.S.

REFERENCES

PLAN No.	TITLE
A1-47775	STD SPS - PUMP STN 7.5kW TO 22kW (VSD) - DIRECT METERED - I & C - DRG INDEX

DESIGNED BY:



DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.		DRAWING No. A1-72835 REV. 1	
DESIGNED: 19/04/2010 - GW/STD		STANDARD SEWERAGE PUMP STATION PUMP STATION 7.5kW TO 22kW (VSD) - DIRECT METERED VSD P18K & AHF 130B1094 (34A) GEAR TRAY LAYOUT	
DRAWN: 29/03/2021 - OPT/RJ			
CHECKED: 31/03/2021 - P STEWART			