



No.	DATE	DESCRIPTION	APP'D	PLAN No.	TITLE
3	9/11/18	CHANGED PHASE FAILURE RELAY (PFR) TYPE.	G.F.		
2	14/9/15	CHANGED PFR TO NORMALLY OPEN.	M.S.		
1	19/8/15	ADDED NEW GW SHT - APPROVED STANDARD DRG.	M.S.		
0	27/3/15	INITIAL ISSUE.	M.S.		

DESIGNED BY:

OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.		DRAWING No. A1-58852 REV. 3	
DESIGNED: 25/03/2015 - M SENANAYAKE DRAWN: 27/03/2015 - OPT/MM CHECKED: 01/04/2015 - M SENANAYAKE		STANDARD SEWERAGE PUMP STATION PUMP STATION 7.5kW TO 22kW (SOFT STARTER) POWER & CONTROL SUPPLIES ELECTRICAL SCHEMATIC DIAGRAM - SHEET 1 OF 2	