



MATERIAL: 3.0mm MARINE GRADE ALUMINUM.

FINISH: TO BE POWDER COATED COLORBOND WILDERNESS GREEN.

HINGES: GRADE 316 STAINLESS STEEL HINGES & PINS
WITH LOCKING WASHERS UNDER FIXING SCREWS.

HANDLES: TO BE SUPPLIED BY CLIENT REQUIRE 3 POINT LOCKING
SYSTEM WITH ROLLER ENDS TO BE SUPPLIED
BY MANUFACTURER ON DOORS.
ALL LOCKS ARE 5Y3.

GEAR PLATES: CONTROL & DISTRIBUTION GEAR TRAY - 1020mm HIGH x 910mm WIDE
TELEMETRY GEAR TRAY - 620mm HIGH x 880mm WIDE
INSTRUMENT GEAR TRAY - 400mm HIGH x 400mm WIDE
TO BE POWDER COATED WHITE & FRONT OF
GEAR TRAY TO BE 25mm FROM WALL.

ESCUTCHEON DOORS: TO BE POWDER COATED WHITE & HAVE M4 CHROMED,
SLOTTED ROUND HEAD THUMB SCREWS WITH
RETAINING CLIP (2 PLACES). TO BE FITTED WITH
CABLE SUPPORT RAILS MOUNTED BEHIND.

EXTERNAL VENTS: B & R EXTERNAL VENT KIT IPVK SUPPLIED WITH GASKET,
INSERT FILTER & FIXINGS OR EQUIVALENT.

PLINTH: ALUMINIUM PREFORMED CHANNEL CONSTRUCTED
IN ONE CONTINUOUS LENGTH.

DOOR SEALS: 5060 PVC / NITRILE 6mm THICK OR EQUIVALENT.

DOOR STAYS: ALL EXTERNAL DOORS TO BE FITTED WITH MECHANICALLY
LOCKING ROD TYPE DOOR STAYS TO KEEP DOOR OPEV AT
A MINIMUM OF 110 DEGREES.



CABLE SUPPORTS: 10 x 25 CABLE SUPPORT RAILS TO BE MOUNTED ON SIDE
OF CABINET'S INTERIOR & ESCUTCHEON AS SHOWN.

NOT TO SCALE

REVIEWS						REFERENCES		
	2	19/8/15	ADDED NEW GW SHT - APPROVED STANDARD DRG.		M.S.			
	1	21/5/15	ADDED HANDLE TO GENERATOR CONNECTION BOX.		M.S.			
	0	27/3/15	INITIAL ISSUE.		M.S.			
	No.	DATE	DESCRIPTION		APP'D		PLAN No.	TITLE

DESIGNED BY:



DO NOT SCALE		GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING		GIPPSLAND WATER FACILITY CODE XXCPRX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.			GIPPSLAND WATER		DRAWING No. A1-58867
DESIGNED: 25/03/2015 - M SENANAYAKE			STANDARD SEWERAGE PUMP STATION PUMP STATION 7.5kw TO 22kw (SOFT STARTER) BACK TO BACK - PUMP STATION CUBICLE GENERAL ARRANGEMENT		
DRAWN: 27/03/2015 - OPT/MM					
CHECKED: 01/04/2015 - M SENANAYAKE					