


**WARNING**  
**BEWARE OF UNDERGROUND SERVICES**  
The locations of underground services are approximate only and their exact position should be proven on site.  
No guarantee is given that all existing services are shown. Locate all underground services before commencement of works  
**DIAL 1100 BEFORE YOU DIG**  
www.1100.com.au

**NOTE:**  
DRIVEWAY ACCESS TRACK TO MEET ALL REQUIREMENTS OF AS2890.2-2002 FOR HEAVY RIGID VEHICLES

**NOTE:**  
ALL "X" DIMENSIONS TO BE REPLACED WITH ACTUAL DIMENSION PRIOR TO FINAL DESIGN

**NOTE:**  
ORIENTATION, SUPPLY LINES, INLETS, OUTLETS & GENERAL INFORMATION ARE ALL EXAMPLES ONLY. CONTRACTOR TO PROVIDE SITE SPECIFIC DETAILS PRIOR TO FINAL DESIGN

**NOTES TO BE ADDED:**  
- LANDSCAPING  
- SIGNAGE  
- FENCING / BOLLARDS / SECURITY  
- DRAINAGE  
- TRUCK ACCESS  
- LIGHTING



LEGEND			
—S—	EX. SEWER MAIN	● MAINTENANCE HOLE (MH)	
—NEW—	NEW SEWER MAIN 225mm DIA. & UNDER	⊙ MAINTENANCE CHAMBER (MC)	
—NEW—	NEW SEWER MAIN ~225mm DIA.	⊙ MAINTENANCE SHAFT (MS)	
—X—	DECOMMISSIONED MAIN	⊙ INSPECTION SHAFT (IS)	
—S—	FUTURE SEWER MAIN	⊙ OBlique JUNCTION	
		—P—	PIPE STUB
		—R—	RETAINING WALL
		—O/H E—	O/H E- O/HEAD POWER
		—E—	U/GROUND POWER
		—W—	WATER MAIN
		—G—	GAS MAIN
		—FOC—	FIBRE OPTICS
		—T—	TELCO CABLE
		—D—	STORMWATER DRAIN

**SITE LAYOUT PLAN**


**SETOUT TABLE**

POINT NO	EASTING	NORTHING	RL
P1	399240.440	5776259.818	95.010
P2	399234.282	5776214.444	95.050
P3	399214.355	5776217.148	95.060
P4	399217.080	5776237.233	95.040
P5	399229.080	5776235.604	95.030
P6	399232.094	5776257.807	95.015
P7	399225.684	5776232.884	95.100
P8	399225.166	5776229.071	95.100
P9	399223.327	5776233.203	95.100

(EXAMPLE LAYOUT ONLY)

STRUCTURAL FILL TO BE PLACED AND COMPACTED TO VICROADS SPEC 204 MINIMUM MDD 95%

STRIP EXISTING SURFACE OF VEGETATION AND TOPSOIL. TYNE AND COMPACT SURFACE TO MIN DEPTH 150mm. COMPACTION TO MINIMUM MDD 95%



**HARDSTAND AREA TYPICAL DETAIL**

REVISIONS		REFERENCES		DESIGNED BY:	
No.	DATE	DESCRIPTION	APP'D	PLAN No.	TITLE
0	28/06/22	INITIAL ISSUE	GM	A1 70471	DRAWING INDEX (CAD MASTER FILE)

DO NOT SCALE

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.

DESIGNED: 13/02/19 GM

CHECKED: 09/04/21 RD/FR

GIPPSLAND WATER

"LOCATION" SEWER RETICULATION SEWAGE PUMP STATION GENERAL SITE LAYOUT

GIPPSLAND WATER FACILITY CODE

TBD

DRAWING No. A1-70473

REV. 0