

DIN RAIL BOOSTED FOR ITEMS  
TO PROTRUDE ESCUTCHEON  
REFER DRG A1-48316

DIN RAIL BOOSTED FOR ITEMS  
TO PROTRUDE ESCUTCHEON  
REFER DRG A1-48316

REVISIONS

No.	DATE	DESCRIPTION	APP'D
18	10/11/20	REVISED ITEMS 7 & 13 COMPONENTS.	P.S.
17	9/11/18	CHANGED PHASE FAILURE RELAY (PFR) TYPE.	G.F.
16	16/11/17	ADDED TOP HAT FOR 24VAC/DC (Bs ADDED REMOTE START INHIBIT RELAY (RSIR).	G.F.
15	12/7/17	REDRAWN IN DGN & REVISED TYPE OF MAIN SWITCH.	P.S.

REFERENCES

PLAN No.	TITLE
A1-47731	STANDARD SPS PUMP STATION UP TO 5.5kW (DOL) - I & C - DRAWING INDEX

DESIGNED BY:



DO NOT SCALE

GIPPSLAND WATER  
DRAWING STATUS

STANDARD DRAWING

GIPPSLAND WATER FACILITY CODE

XXCPXX


DRAWING No.

A1-47750

REV.

18

CERTIFICATION OF  
COMPLIANCE WITH  
GIPPSLAND WATER'S  
DESIGN & DRAFTING  
REQUIREMENTS.  
DESIGNED:  
12/07/2017 - STD DRG  
DRAWN:  
12/07/2017 - OPT/RJ  
CHECKED:  
19/07/2017 - P STEWART



GIPPSLAND WATER

STANDARD SEWERAGE PUMP STATION  
PUMP STATION UP TO 5.5kW (DOL)  
CONTROL & DISTRIBUTION COMPARTMENT (PF1ED01)  
GEAR TRAY LAYOUT