

Briagolong PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Briagolong (Bores - Raw Water)				Briagolong (water entry point)			
	PERFLUORO BUTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (PFOS)	PERFLUORO CTANOIC ACID (PFOA)	PERFLUORO BUTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (PFOS)	PERFLUORO CTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
25-Apr-17	<0.002	<0.002	<0.002	<0.002				
08-Aug-17	<0.002	<0.002	<0.002	<0.002				
05-Sep-17	<0.002	0.026	0.002	<0.002				
12-Sep-17	<0.002	<0.002	0.004	<0.002				
10-Oct-17	<0.002	<0.002	<0.002	<0.002				
14-Nov-17					<0.002	<0.002	<0.002	<0.002
16-Nov-17	<0.002	<0.002	<0.002	<0.002				
12-Dec-17	<0.002	<0.002	<0.002	<0.002				
13-Feb-18	<0.002	<0.002	<0.002	<0.002				
27-Feb-18					<0.002	<0.002	<0.002	<0.002
13-Mar-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
10-Apr-18						<0.002	<0.002	<0.002
11-Apr-18		<0.002	<0.002	<0.002				
07-May-18			<0.002	<0.002		<0.002	<0.002	<0.002
12-Jun-18	<0.002	<0.002	<0.002	<0.002				
13-Jun-18					<0.002	<0.002	<0.002	<0.002
05-Jul-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
14-Aug-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
07-Sep-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
10-Sep-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
04-Oct-18					<0.002	<0.002	<0.002	<0.002
09-Oct-18		<0.002	<0.002	<0.002				
12-Oct-18					<0.002	<0.002	<0.002	<0.002
04-Nov-18	<0.002	<0.002	<0.002	<0.002				
09-Nov-18	<0.002	<0.002	<0.002	<0.002				
12-Nov-18	<0.002	<0.002	<0.002	<0.002				
13-Nov-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
06-Dec-18	<0.002	<0.002	<0.002	<0.002				
09-Dec-18					<0.002	<0.002	<0.002	<0.002
07-Jan-19						<0.002	<0.002	<0.002
12-Feb-19		<0.002	<0.002	<0.002		<0.002	<0.002	<0.002
12-Mar-19		<0.002	<0.002	<0.002		<0.002	<0.002	<0.002
09-Apr-19		<0.002	<0.002	<0.002		<0.002	<0.002	<0.002
13-May-19					<0.002	<0.002	<0.002	<0.002
14-May-19	<0.002	<0.002	<0.002	<0.002				
11-Jun-19		<0.002	<0.002	<0.002		<0.002	<0.002	0.003
01-Jul-19					<0.002	<0.002	<0.002	<0.002
10-Jul-19					<0.002	<0.002	<0.002	<0.002
01-Aug-19	<0.002	<0.002	<0.002	<0.002				
07-Aug-19					<0.002	<0.002	<0.002	<0.002
13-Aug-19					<0.002	<0.002	<0.002	<0.002
15-Aug-19	<0.002	<0.002	<0.002	<0.002				
04-Sep-19	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
07-Sep-19	<0.002	<0.002	<0.002	<0.002				
09-Sep-19					<0.002	<0.002	<0.002	<0.002
12-Sep-19					<0.002	<0.002	<0.002	<0.002
09-Oct-19	<0.002	<0.002	<0.002	<0.002				
10-Oct-19	<0.002	<0.002	<0.002	<0.002		<0.002	<0.002	<0.002

21-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
10-Dec-24	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
13-Jan-25	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
10-Feb-25	<0.002	<0.002	<0.002	<0.002				
12-Feb-25					<0.002	<0.002	<0.002	<0.002
11-Mar-25	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
14-Apr-25	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
12-May-25	<0.002	<0.002	<0.002	<0.002				
27-May-25					<0.002	<0.002	<0.002	<0.002
10-Jun-25	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
08-Jul-25	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
12-Aug-25					<0.002	<0.002	<0.002	<0.002
11-Nov-25					<0.002	<0.002	<0.002	<0.002
10-Feb-26					<0.002	<0.002	<0.002	<0.002
10-Mar-26	<0.002	<0.002	<0.002	<0.002				

Heyfield PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Heyfield - Thompson River (Pump Station)				Heyfield (water entry point)			
	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
21-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
11-Aug-25					<0.002	<0.002	<0.002	<0.002
10-Nov-25					<0.002	<0.002	<0.002	<0.002
10-Feb-26					<0.002	<0.002	<0.002	<0.002
11-Mar-26	<0.002	<0.002	<0.002	<0.002				

Maffra PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Maffra - Macalister River (Pump Station)				Maffra (McAdam Street Tank Outlet)			
	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
21-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
12-Aug-25					<0.002	<0.002	<0.002	<0.002
12-Nov-25					<0.002	<0.002	<0.002	<0.002
11-Feb-26					<0.002	<0.002	<0.002	<0.002
12-Mar-26	<0.002	<0.002	<0.002	<0.002				

Mirboo North PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Mirboo North - Little Morwell River				Mirboo North (water entry point)			
	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
19-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
14-Aug-25					<0.002	<0.002	<0.002	<0.002
12-Nov-25					<0.002	<0.002	<0.002	<0.002
09-Feb-26					<0.002	<0.002	<0.002	<0.002
11-Mar-26	<0.002	<0.002	<0.002	<0.002				

Moe PFAS Testing

Sample Date	Raw Water								Drinking Water			
	Moe - Tanjil River				Moe - Narracan Creek				Moe (water entry point)			
	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
19-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005	<0.0005	<0.0005	<0.0003	<0.0005	<0.002	<0.002	<0.002	<0.002
11-Aug-25									<0.002	<0.002	<0.002	<0.002
11-Nov-25									<0.002	<0.002	<0.002	<0.002
09-Feb-26									<0.002	<0.002	<0.002	<0.002
10-Mar-26	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002				

=====

Morwell PFAS Testing

Sample Date	Raw Water												Drinking Water												
	Moondarra (pipeline sample)						Moondarra (surface sample)						Tyers (water entry point)				Traralgon (water entry point)				Morwell (water entry point)				
	PERFLUORO UTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (POA)	PERFLUORO OCTANOIC ACID (PFOS)	PERFLUORO UTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (POA)	PERFLUORO OCTANOIC ACID (PFOS)	PERFLUORO UTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (POA)	PERFLUORO OCTANOIC ACID (PFOS)	PERFLUORO UTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (POA)	PERFLUORO OCTANOIC ACID (PFOS)	PERFLUORO UTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (POA)	PERFLUORO OCTANOIC ACID (PFOS)					
	1.0	0.03	0.005	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	
Australian Drinking Water Guideline Value (µg/L)																									
01-Dec-24	<0.0005	<0.0005	<0.0003	<0.0003	<0.0005	<0.0005	<0.0003	<0.0005	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	
11-Aug-25																									
13-Aug-25																									
13-Nov-25																									
09-Feb-26																									
10-Feb-26																									
11-Mar-26	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	

=====

Neerim South PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Neerim South - Tarago Reservoir (Pump Station)				Neerim South (water entry point)			
	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
26-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
12-Aug-25					<0.002	<0.002	<0.002	<0.002
11-Nov-25					<0.002	<0.002	<0.002	<0.002
12-Feb-26					<0.002	<0.002	<0.002	<0.002
12-Mar-26	<0.002	<0.002	<0.002	<0.002				

Rawson PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Rawson - Trigger Creek				Rawson (water entry point)			
	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)	PERFLUOROB UTANE SULFONIC ACID (PFBS)	PERFLUOROH EXANE SULFONIC ACID (PFHxS)	PERFLUOROO CTANE SULFONIC ACID (PFOS)	PERFLUOROO CTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
27-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
12-Aug-25					<0.002	<0.002	<0.002	<0.002
11-Nov-25					<0.002	<0.002	<0.002	<0.002
10-Feb-26					<0.002	<0.002	<0.002	<0.002
12-Mar-26	<0.002	<0.002	<0.002	<0.002				

Seaspray PFAS Testing

Sample Date	Raw Water				Drinking Water			
	Seaspray (Merriman Creek - Basin)				Seaspray (water entry point)			
	PERFLUORO BUTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (PFOS)	PERFLUORO CTANOIC ACID (PFOA)	PERFLUORO BUTANE SULFONIC ACID (PFBS)	PERFLUORO HEXANE SULFONIC ACID (PFHxS)	PERFLUORO OCTANE SULFONIC ACID (PFOS)	PERFLUORO CTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
14-Mar-17	<0.002	<0.002	<0.002	<0.002				
26-Apr-17	<0.002	<0.002	<0.002	<0.002				
09-May-17				<0.002				
08-Aug-17	<0.002	<0.002	<0.002	<0.002				
05-Sep-17	<0.002	0.047	0.003	<0.002				
12-Sep-17	<0.002	<0.002	0.003	<0.002				
10-Oct-17	<0.002	<0.002	<0.002	<0.002				
13-Nov-17					<0.002	<0.002	<0.002	<0.002
16-Nov-17	<0.002	<0.002	<0.002	<0.002				
12-Dec-17	<0.002	<0.002	<0.002	<0.002				
13-Feb-18	<0.002	<0.002	<0.002	<0.002				
28-Feb-18					<0.002	<0.002	<0.002	<0.002
13-Mar-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
10-Apr-18		<0.002	<0.002	<0.002				
11-Apr-18						<0.002	<0.002	<0.002
08-May-18		<0.002	<0.002	<0.002				
09-May-18						<0.002	<0.002	<0.002
12-Jun-18		<0.002	<0.002	<0.002				
14-Jun-18					<0.002	<0.002	<0.002	<0.002
10-Jul-18		<0.002	<0.002	<0.002				
11-Jul-18						<0.002	<0.002	<0.002
05-Aug-18	<0.002	<0.002	<0.002	<0.002				
14-Aug-18	<0.002	<0.002	<0.002	<0.002				
15-Aug-18					<0.002	<0.002	<0.002	<0.002
05-Sep-18					<0.002	<0.002	<0.002	<0.002
10-Sep-18	<0.002	<0.002	<0.002	<0.002				
04-Oct-18	<0.002	<0.002	<0.002	<0.002				
07-Oct-18	<0.002	<0.002	<0.002	<0.002				
10-Oct-18					<0.002	<0.002	<0.002	<0.002
04-Nov-18					<0.002	<0.002	<0.002	<0.002
07-Nov-18					<0.002	<0.002	<0.002	<0.002
09-Nov-18	<0.002	<0.002	<0.002	<0.002				
12-Nov-18	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
13-Nov-18	<0.002	<0.002	<0.002	<0.002				
14-Nov-18					<0.002	<0.002	<0.002	<0.002
06-Dec-18	<0.002	<0.002	<0.002	<0.002				
09-Dec-18					<0.002	<0.002	<0.002	<0.002
08-Jan-19		<0.002	<0.002	<0.002				
09-Jan-19							<0.01	<0.01
13-Mar-19	<0.002	<0.002	<0.002	<0.002				
14-Mar-19					<0.002	<0.002	<0.002	<0.002
09-Apr-19		<0.002	<0.002	<0.002				
10-Apr-19						<0.002	<0.002	<0.002
14-May-19	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
12-Jun-19						<0.002	<0.002	<0.002
09-Jul-19		<0.002	<0.002	<0.002		<0.002	<0.002	<0.002
01-Aug-19	<0.002	<0.002	<0.002	<0.002				
10-Aug-19	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002

08-Feb-22	<0.002	<0.002	<0.002	<0.002				
09-Feb-22					<0.002	<0.002	<0.002	<0.002
08-Mar-22	<0.002	<0.002	<0.002	<0.002				
16-Mar-22					<0.002	<0.002	<0.002	<0.002
12-Apr-22	<0.002	<0.002	<0.002	<0.002				
19-Apr-22					<0.002	<0.002	<0.002	<0.002
10-May-22					<0.002	<0.002	<0.002	<0.002
24-May-22	<0.002	<0.002	<0.002	<0.002				
14-Jun-22	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
16-Jun-22					<0.002	<0.002	<0.002	<0.002
12-Jul-22	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
02-Aug-22	<0.002	<0.002	<0.002	<0.002				
03-Aug-22	<0.002	<0.002	<0.002	<0.002				
09-Aug-22	<0.002	<0.002	<0.002	<0.002				
02-Sep-22					<0.002	<0.002	<0.002	<0.002
13-Sep-22	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
11-Oct-22	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
01-Nov-22	<0.002	<0.002	<0.002	<0.002				
15-Nov-22	<0.002	<0.002	<0.002	<0.002				
16-Nov-22					<0.002	<0.002	<0.002	<0.002
01-Dec-22					<0.002	<0.002	<0.002	<0.002
04-Dec-22	<0.002	<0.002	<0.002	<0.002				
12-Dec-22	<0.002	<0.002	<0.002	<0.002				
13-Dec-22					<0.002	<0.002	<0.002	<0.002
10-Jan-23	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
14-Feb-23	<0.002	<0.002	<0.002	<0.002				
16-Feb-23					<0.002	<0.002	<0.002	<0.002
15-Mar-23	<0.002	<0.002	<0.002	<0.002				
16-Mar-23					<0.002	<0.002	<0.002	<0.002
12-Apr-23	<0.002	<0.002	0.003	<0.002				
13-Apr-23					<0.002	<0.002	<0.002	<0.002
09-May-23	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
13-Jun-23	<0.002	<0.002	<0.002	<0.002				
15-Jun-23					<0.002	<0.002	<0.002	<0.002
11-Jul-23	<0.002	<0.002	<0.002	<0.002				
12-Jul-23					<0.002	<0.002	<0.002	<0.002
14-Aug-23					<0.002	<0.002	<0.002	<0.002
15-Aug-23	<0.002	<0.002	<0.002	<0.002				
11-Sep-23					<0.002	<0.002	<0.002	<0.002
12-Sep-23	<0.002	<0.002	<0.002	<0.002				
10-Oct-23					<0.002	<0.002	<0.002	<0.002
16-Nov-23					<0.002	<0.002	<0.002	<0.002
11-Dec-23	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
08-Jan-24	<0.002	<0.002	<0.002	<0.002				
09-Jan-24					<0.002	<0.002	<0.002	<0.002
13-Feb-24	<0.002	<0.002	<0.002	<0.002				
14-Feb-24					<0.002	<0.002	<0.002	<0.002
12-Mar-24					<0.002	<0.002	<0.002	<0.002
13-Mar-24	<0.002	<0.002	<0.002	<0.002				
09-Apr-24	<0.002	<0.002	<0.002	<0.002				
11-Apr-24					<0.002	<0.002	<0.002	<0.002
14-May-24	<0.002	<0.002	<0.002	<0.002				
15-May-24					<0.002	<0.002	<0.002	<0.002
13-Jun-24					<0.002	<0.002	<0.002	<0.002
09-Jul-24	<0.002	<0.002	<0.002	<0.002				
10-Jul-24					<0.002	<0.002	<0.002	<0.002
12-Aug-24	<0.002	<0.002	<0.002	<0.002				
14-Aug-24					<0.002	<0.002	<0.002	<0.002

11-Sep-24					<0.002	<0.002	<0.002	<0.002
16-Sep-24	<0.002	<0.002	<0.002	<0.002				
08-Oct-24	<0.002	<0.002	<0.002	<0.002				
15-Oct-24					<0.002	<0.002	<0.002	<0.002
12-Nov-24	<0.002	<0.002	<0.002	<0.002				
13-Nov-24					<0.002	<0.002	<0.002	<0.002
21-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005				
10-Dec-24	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002
13-Jan-25	<0.002	<0.002	<0.002	<0.002				
14-Jan-25					<0.002	<0.002	<0.002	<0.002
10-Feb-25	<0.002	<0.002	<0.002	<0.002				
12-Feb-25					<0.002	<0.002	<0.002	<0.002
11-Mar-25	<0.002	<0.002	<0.002	<0.002				
13-Mar-25					<0.002	<0.002	<0.002	<0.002
08-Apr-25	<0.002	<0.002	<0.002	<0.002				
15-Apr-25					<0.002	<0.002	<0.002	<0.002
12-May-25	<0.002	<0.002	<0.002	<0.002				
13-May-25					<0.002	<0.002	<0.002	<0.002
10-Jun-25	<0.002	<0.002	<0.002	<0.002				
11-Jun-25					<0.002	<0.002	<0.002	<0.002
10-Jul-25	<0.002	<0.002	<0.002	<0.002				
14-Aug-25					<0.002	<0.002	<0.002	<0.002
12-Nov-25					<0.002	<0.002	<0.002	<0.002
12-Feb-26					<0.002	<0.002	<0.002	<0.002
12-Mar-26	<0.002	<0.002	<0.002	<0.002				

Thorpdale PFAS Testing

Sample Date	Drinking Water			
	Thorpdale (water entry point)			
	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2
13-Aug-25	<0.002	<0.002	<0.002	<0.002
11-Nov-25	<0.002	<0.002	<0.002	<0.002
09-Feb-26	<0.002	<0.002	<0.002	<0.002

Warragul PFAS Testing

Sample Date	Raw Water												Drinking Water						
	Warragul				Warragul - Tangee River				Warragul - Tangee Reservoir				Warragul						
	Water Treatment Plant (WTP)				Pre-treatment (PT)				Pre-treatment (PT)				Water Treatment Plant (WTP)						
	Perfluorooctanoic acid (PFOA)	Perfluorooctane sulfonate (PFOS)	Perfluorodecanoic acid (PFDA)	Perfluorododecanoic acid (PFDDA)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)	Perfluorododecane sulfonate (PFDS)
	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10-Nov-20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10-Dec-20	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10-Jan-21	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10-Feb-21	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10-Mar-21	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Willow Grove PFAS Testing

Sample Date	Raw Water								Drinking Water			
	Willow Grove - Blue Rock Reservoir (Water Treatment Plant Inlet)				Willow Grove - Blue Rock Reservoir (Boat Ramp)				Willow Grove (water entry point)			
	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)	PERFLUOROBUTANE SULFONIC ACID (PFBS)	PERFLUOROHXANE SULFONIC ACID (PFHxS)	PERFLUOROOCTANE SULFONIC ACID (PFOS)	PERFLUOROOCTANOIC ACID (PFOA)
Australian Drinking Water Guideline Value (ug/L)	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2	1.0	0.03	0.008	0.2
30-Nov-24	<0.0005	<0.0005	<0.0003	<0.0005	<0.0005	<0.0005	<0.0003	<0.0005				
12-Aug-25									<0.002	<0.002	<0.002	<0.002
12-Feb-26									<0.002	<0.002	<0.002	<0.002
11-Mar-26	<0.002	<0.002	<0.002	<0.002								